


*"Laboratory is a Temple where Search for Truth is actually made"*

**ESTD-1974**



**DR. UPPAL'S  
TESTING & ANALYTICAL  
LABORATORY (P) LTD.**  
A GOVT. APPROVED LABORATORY

Cell : 09779180240, 09872622353

09888016830

Phones : Off. 0172-5097240,

Website : www.utralabindia.com

Grams : UTALAB

**SPECIALIST IN :**

Soil Investigation & Testing for all types of Structure  
Metallurgical Testing, Material Testing, Mix Designs  
(Concrete, Bituminous, Mastic, Filtermedia)  
Assessment of Road Crust/Overlay Thickness by  
CBR and Benkelman Beam Deflection Techniques,  
Water Testing for Industrial, Drinking & Construction  
purpose etc.

**WORKS :** 240, Industrial Area,  
Phase IX, S.A.S. Nagar, Mohali  
Email : servicesutralabindia@yahoo.com



ISO 9001:2015  
Quality Management System  
Cert. No. 22EQHO29

**TEST REPORT**

**PAGE 1 OF 1**

To, <b>The Doon Public School, Sector-21, Panchkula.</b>	Lab Id No.	: UTALAB/25/085/2
	Date of issue	: 12.05.2025
	Date of Testing	: 07.05.2025-12.05.2025
Product: Water.	Date of receipt	: 07.05.2025
Condition: Bottle.	Your Ref.	: Letter Dtd: 07.05.2025
Identification:--	Specification followed	: IS: 10500-2012

**Description:** A clear colorless liquid contained in a amber colored glass bottle.

Sl. No.	Parameters	Test Method	Results	IS: 10500 Limits	
				Desirable	Permissible
1.	pH value	IS:3025 (P-11)	7.4	6.5-8.5	No relaxation
2.	Colour	IS:3025 (P-4)	Less than 1	Max 05	Max 15
3.	Turbidity (NTU)	IS:3025 (P-10)	00	Max 01	Max 5
4.	Chloride (as Cl) - mg/l	IS: 3025 (P-32)	14.9	Max 250	Max 1000
5.	Total Hardness (as CaCO <sub>3</sub> ) -mg/l	IS: 3025 (P-21)	230.4	Max 200	Max 600
6.	Sulphate (as SO <sub>4</sub> ) -mg/l	IS: 3025 (P-24)	40	Max 200	Max 400
7.	Total Dissolved Solids (TDS)-mg/l	IS:3025 (P-16)	456	Max 500	Max 2000
8.	Iron (as Fe)-mg/l	IS:3025 (P-53)	Not Detectable	Max 1.0	No relaxation
9.	Nitrate (as NO <sub>3</sub> )-mg/l	IS:3025 (P-34)	2.8	Max 45	No relaxation
10.	Microbiological Examination: E coli per100ml	IS: 1622	Not Detectable	Should be absent	No Relaxation

**Remarks:** The above submitted sample of water conforms to IS: 10500 (drinking purpose) w.r.t above tests within permissible limits.

**REVIEWED BY**

**PRINCIPAL**

**Doon Public School  
Sector-21, Panchkula HR**

**MANAGER**

**Doon Public School  
Sector-21, Panchkula HR**

**NOTES**

1. Sample collected by the client / laboratory
2. The results relate only to the sample tested
3. Test certificate shall not be reproduced in full or part & cannot be used as an evidence in the courts of law without the written approval of the laboratory
4. Sample will be destroyed after one month from the completion date of test item unless specified sample liable to decompose will be destroyed after testing.

**\*\*\* END OF THE REPORT \*\*\***



# हरियाणा शहरी विकास प्राधिकरण

OFFICE OF THE SUB DIVISIONAL ENGINEER,  
HSVP, SUB DIVISION No-IV, PANCHKULA.  
Address- SCF-65, Sector-8, Panchkula.



To,

The Doon Public School,  
Sr. Sec. School,  
Sector-21 Panchkula (Hry).

Memo No. 141411

Dated:- 21/5/25

**Sub:- Regarding safe drinking water facility certificate.**

Please refer to your office letter no. DSP/P/23-B/7351/25-26 dated 28.04.2025 on above cited subject.

As requested vide letter under reference, it is certified that the water being supplied to Doon Public School Sector-21 Panchkula is safe for drinking purpose.

Sub Divisional Engineer,  
HSVP, Sub Division No. IV,  
Panchkula.

**Endst No.**

**Dated.**

A copy of the above is forwarded to the following for information and further necessary action please.

1. The Executive Engineer, HSVP, Division No. I, Panchkula.
2. Sh. Ashok Kumar, J.E with respect to his site report dated 28.04.2025.

Sub Divisional Engineer,  
HSVP, Sub Division No. IV,  
Panchkula.

PRINCIPAL  
Doon Public School  
Sector-21, Panchkula HR

MANAGER  
Doon Public School  
Sector-21, Panchkula HR




## HYGIENE CERTIFICATE

It is certified that inspection with regard to maintenance of Healthy Surrounding and Hygienic sanitization condition of Doon Public School Sector-21, Panchkula was carried out on dated 25-04-2025.

As per observation, proper health and sanitation condition have been found. The school has proper ventilation, facility for drinking water, garbage disposal and toilet facilities with hygienic conditions.

The sample of drinking water found to be 220 ppm TDS.

This certificate is valid for two years from date of issue w.e.f. 25.04.2025.

  
Medical Officer  
UHW  
Sector-15, Panchkula

Dispatch No. 267  
UHWIC

Dated: 25/04/2025

To

The Principal  
Doon Public School  
Sector-21, Panchkula

  
PRINCIPAL  
Doon Public School  
Sector-21, Panchkula HR

  
MANAGER  
Doon Public School  
Sector-21, Panchkula HR